






FIRE ACTIVITY REPORT

City of West Hollywood | February 2022



ALS Transports: accompanied by paramedic; **BLS Transports:** no paramedic on board

*Patients Seen total will be higher than Medical Calls total in first graph if there were multiple patients at one incident.



FIRE ACTIVITY REPORT

City of West Hollywood | February 2022

FIRE INCIDENTS:

DATE	TYPE	ADDRESS	NOTES	LOSS
02/01/22	Fire, other	8941 SANTA MONICA Blvd	Outdoor fire/heating device in-front of bar tipped over. No fire aid needed.	
02/04/22	Cooking Fire	1046 SIERRA BONITA Ave	Food on the stove. After no answer, FD had to force entry. The unit was full of smoke due to burnt food. Smoke detectors were functioning but did not alert the occupant.	Property: \$0.00 Contents: \$100.00
02/07/22	Vehicle Fire	8800 BEVERLY Blvd	Vehicle fire extinguished using a dry chemical extinguisher.	Property: \$2,000.00 Contents: \$0.00
02/09/22	Rubbish Fire	SANTA MONICA Blvd		
02/14/22	Rubbish Fire	1234 LA BREA Ave	Fire in trash can outside front entrance activated one sprinkler head. Fire out prior to arrival.	
02/23/22	Rubbish Fire	SANTA MONICA Blvd		
			TOTAL:	Property: \$2,000.00 Contents: \$100.00

OTHER INCIDENTS:

DATE	TYPE	ADDRESS	NOTES	LOSS
02/02/22	Haz Cond	840 LARRABEE St	Gas leak (natural gas or LPG); Tenant found stove partially on.	
02/04/22	Haz Cond	750 SAN VICENTE Blvd	Gas leak (natural gas or LPG); Construction crews working on gas line in area.	
02/09/22	Haz Cond	CORY Ave	Electrical wiring/equipment problem, other. Communication line down. Line cut and removed from the street.	
02/13/22	HazMat	1033 CAROL Dr	Gasoline or other flammable liquid spill; small fuel leak from car onto asphalt road, LF8 used duck seal to slow the leak and applied dirt on ground to soak up the existing spilled fuel.	
02/28/22	Haz Cond	1109 VISTA St	Arcing, shorted electrical equipment.	