




FIRE ACTIVITY REPORT

City of West Hollywood | October 2024







Advanced Life Support (ALS) Transports: transported to hospital in ambulance with paramedic on board;

Basic Life Support (BLS) Transports: transported without paramedic on board

FIRE INCIDENTS:

DATE	TYPE	ADDRESS	NOTES	LOSS
10/03/24	Vehicle Fire	CLARK St & SUNSET	Mobile property; vehicle fire	
10/04/24	Rubbish Fire	949 KINGS Rd	Rubbish fire, confined to container	
10/08/24	Rubbish Fire	8430 SUNSET Blvd	Rubbish fire, confined to container	
10/09/24	Rubbish Fire	SANTA MONICA & VISTA	Rubbish fire, confined to container	
10/10/24	Structure Fire	1146 HACIENDA PI	Small fire caused by a sparking electrical outlet caused the dresser next to the outlet to catch on fire. The fire caused a one sprinkler head activation. Flooding the apartment involved on the third floor and subsequently flooding the apartments below it. The major water damage was estimated to have a monetary loss of ~\$100,000 in structural damage and ~\$30,000 in contents damaged by either fire or water.	Property: \$100,000.00 Contents: \$30,000.00
10/14/24	Cooking Fire	1274 CRESCENT HEIGHTS	Burnt food in oven; no extension	
10/23/24	Fire, other	1411 FAIRFAX Ave	Mattress fire out on arrival in bedroom of a second story unit in an apt complex. Residents used dry chemical fire extinguisher on the mattress.	
			TOTAL:	Property: \$100,000.00 Contents: \$30,000.00

OTHER INCIDENTS:

DATE	TYPE	ADDRESS	NOTES	LOSS
10/08/24	Haz Cond	1047 SIERRA BONITA	Electrical wiring/equipment problem, other	
10/25/24	Haz Cond	BEVERLY & DOHENY	Gas leak (natural gas or LPG)	